



CERTIFICATE

UK APPROVAL

Certificate Number: 1908737

Date Issued: 27 August 2019

Date Expired: 26 August 2024

Description: Range of lever operated spherical valves with either brass bodies with brass balls and PTFE seats. Maximum working pressure 25.0 bar. Maximum operating pressure 100°C.

Product Designation: 771635R, 771635B, 771636R, 761636B, 771637R, 771637B, 771638R, 771638B, 771639R, 771639B
Where 'R' denotes a red PVC coated handle and 'B' a blue PVC coated handle

This is to certify that the above range of products manufactured / supplied by

Company Name: Sanbra Fyffe Ltd

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2014, Scotland and the Water Regulations Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRN's) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRN's for this certificate – R001

Authorised Signature

Kiwa Watertec
(A Trading Division of
Kiwa Ltd)
Unit 26A
Rassau Industrial Estate
Ebbw Vale, Gwent,
NP23 5SD
UNITED KINGDOM
Tel: 0044 (0) 1495 308185
Web: www.kiwa.co.uk

Certificate Issued to –
Sanbra Fyffe Ltd
Instantor Works
Santry Avenue
Santry
Dublin
Ireland
D09 K160



Date: 27 August 2019

Our Ref: 1908737
Sample No: S190539

Sanbra Fyffe Ltd
Instantor Works
Santry Avenue
Santry
Dublin
Ireland
D09 K160

Kiwa Ltd

Unit 26a, Rassau Industrial Estate
Rassau
Ebbw Vale
Gwent
NP23 5SD

+44 (0)1495 308185
uk.water@kiwa.com

www.kiwa.co.uk/water

Dear Sir,

1. Samples of fittings or units described below have been subjected to relevant tests and examinations contained in the "UK Regulators Specification", and after considering the test reports, Kiwa Ltd finds that the fittings or units so described, comply with, when correctly installed, the requirements of the UK Water Supply (Water Fittings) Regulations 1999, The water supply (water fittings) Byelaws 2014 Scotland and the Water Supply (Water Fittings) Regulations (Northern Ireland) 2009.

DIRECTORY INDEX CATEGORY 2260

VALVES

Spherical - Metal

IRN: R001

Range of lever operated spherical valves with either brass bodies with brass balls and PTFE seats. Maximum working pressure 25.0 bar. Maximum operating pressure 100°C.

Size: 1/4", 3/8", 1/2", 3/4", 1" BSP(F) inlet / outlet connections

Model: 771635R
771635B
771636R
761636B
771637R
771637B
771638R
771638B
771639R
771639B

Where 'R' denotes a red PVC coated handle and 'B' a blue PVC coated handle

Marking: Company logo, date MM/YY, DN, PN on body. Instantor, direction of flow and size on handle

Factor: Sanbra Fyffe Ltd

2. Installation Requirements & Notes are set out at the end of this approval letter.



3. Fittings or units (and any non-metallic components within them) are re-assessed and, where necessary, retested every 5 years. You will be advised when your product is due for re-assessment. The extent of any retesting required for a product will be at the discretion of the Technical Manager.
4. Acceptance for listing entitles the applicant to identify your product with the Scheme's (Kiwa Water Regulations Approval Scheme) mark. The use of the Mark will make the identification easier of the approved products by the Water Undertakers. Copies of the Mark are available on request for the purposes of producing artwork.
5. Manufactures or applicants may only quote in their sales literature, items used in this letter when indicating the decision of the Scheme in respect to their fittings or units, namely that the use of these fittings or units, when correctly installed, will not contravene the requirements of the Water Supply (Water Fittings) Regulations 1999, Water Byelaws 2004 Scotland or Water Regulations (Northern Ireland) 2009 and that a reference to the fittings or units will be included in the Scheme's web site.
6. Since the incorrect installation of water fittings could result in contravention of the Regulations or Byelaws requirements, the attention of your customers should be drawn to any Installation Requirements for Regulations or Byelaws compliance set out on Page 3.
7. Would you please supply the Scheme with a copy of any of your company literature, which may or will make reference to the Scheme's decisions about the products and/or quotes any of the installation requirements.
8. A condition of listing is that no modifications to these fittings or units described above shall be made without first notifying the Scheme and submitting to the Scheme details of the modifications and, if so required, samples of the fittings or units as so modified for consideration by the Scheme. Failure to comply with this condition may result in the removal from the Scheme's listing for the entry relating to the fittings or units in question.
9. Your products are requested to be replicas of the samples described above, and the right is reserved to carry out quality surveillance inspections of your production arrangements, reasonable written notice of which will be given.
10. Please note that the use of the items described in any particular area of supply is at the discretion of the Local Water Undertaking.
11. Manufactures or factors having appliances or units referred to in the Scheme's listing which incorporated individually approved components and materials are asked to ensure that such components and materials continue to be approved and/or listed in the relevant approved listings, during the current period of approval of their appliance. This may require modifications to approved appliances to ensure their retention in the Scheme's listings. The Scheme must be informed of any modifications (See Paragraph 8).
12. You are asked to verify the details of your products as set out in Paragraph 1 and advise us of any discrepancies.

Yours faithfully

A handwritten signature in blue ink, appearing to read 'DJ', with a horizontal line extending to the right.

David Jay
Business Manager

Installations Requirements & Notes.

IRN R001

See text of entry for Installation Requirements or Notes.