



Certificate number: 2410829 (1)

Issued 04/11/2024

Expires 04/11/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Sanbra Fyffe Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Sanbra Fyffe Ltd
Instantor Works
Santry Ave
Dublin
DO9 K160
Ireland



KUKreg4

Product Certificate

Appendix to Certificate number: 2410829

The following products belong to this certificate

PRODUCT DESCRIPTION Range of Instantor lever action ball valves with brass bodies and PTFE seals. ATS3 – Without Production Surveillance.
MODEL(S) 771719R 15mm compression Instantor LABV 771719B 15mm compression Instantor LABV
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 25.0 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.
MARKING Instantor, WRAS, dimension and arrow indicator printed on lever. MOP5, dimension, 'S' logo and size stamped on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes